Voltage

Fuel

Frequency

Performance class

Acoustic pressure LpA

Acoustic power LwA

QEP 4 50Hz 1p

QEP Range



Power ratings			
Prime	Standby	Standby	
kVA	kW	kVA	
3.3	3.5	3.9	
r		0.9	
	Prime kVA	Prime Standby kVA kW 3.3 3.5	

Fuel consumption table

Load level	PRIME	Aut. (h)
	(L/h)	
75%	0.93	3.76
100%	1.24	2.82

Genset Image for illustration purposes only

Mechanical structure			
Length (L)	(mm)	760	
Width (W)	(mm)	540	
Height (H)	(mm)	560	
Weight	(kg)	54	
Fuel tank capacity	(1)	3.5	
Wheels and handles		Optional	

Technical data

(V)

(Hz)

(dB(A) @7m)

(dB(A))


230

50

Diesel

G1

Dimensions



Note: These drawings are provided for illustration purposes only.

Engine

•			
General			
Engine Brand		Yanmar	
Engine Model		L70	
R.P.M.		3000	
Net Power	(kWm)	4.50	
Fuel		Diesel	
No. of cylinders		1	
Displacement	(cm³)	320	
Regulation type		Mechanic	

Lubrication System			
Oil capacity	(1)	1.1	
Engine Oil Guard		YES	

Cooling Sy	ystem
Cooling type	Air

Starting	system
Recoil	YES
Electric 12V	NO

Alternator

Alternator brand		NSM
Alternator model		K100E
IP alternator		IP23
Peak power 163°/27°	(kVA)	4,54
Poles		2
Excitation system		Capacitor
Excitation system		Brushless
Efficiency at 100% 125°/40°	(%)	73

1633103208

Please, contact your local Atlas Copco Dealer for more information

QEP 4 50Hz 1p2014EN2.0



Mains features and options

•

- Mains features
 Recoil start
- Fuel Cock
- Engine Oil Guard
- Sockets

Sockets configuration

SCHUKO 230V 16A IP54 2P+T CEE 230V 16A IP44 1

Options

- Wheel kit
- Differential circuit breaker, hourmeter (ELR)

Regulations:

The generator set has a CE Marking that includes the following directives:

- 2006/42/CE Machine Safety.
- 2006/95/CEE Low Voltage.
- 2004/108/CE Electromagnetic compatibility.

Definitions

Prime Rating

PRIME POWER: Electrical power data available at a variable load without limits of hours per year. An overload of 10 % is allowed for 1 hour of every 12. In accordance with ISO 8528/1 (2005) – PRP

Standby

STANDBY POWER: Electrical power data at variable load in an emergency in accordance with standard ISO 8528/1 (2005) – ESP. Overloads of emergency power are not allowed.

Grupos Electrógenos Europa, S.A. is a certified company with ISO 9001, ISO 14001, OHSAS 18001 and PECAL Atlas Copco reserves the right to modify any characteristic of their equipment without prior warning.

All products are designed and engineered in Zaragoza Competence Center

Weight and dimensions of a standard generator set.

Non-contractual document

Grupos Electrógenos Europa, S.A.

Central Offices:

Polígono pitarco II - Parcela 20 50450 Muel (Zaragoza) España

Tel.: +34 976 145 432 Fax.: +34 976 145 431

STRIBUTED BY:		

Please, contact your local Atlas Copco Dealer for more information

QEP 4 50Hz 1p2014EN2.0

